
### CP3 - Open-loop groundwater source heat pumps Harnessing energy from water in the ground for heating and cooling

Open-loop groundwater source heat pumps: Code of Practice for the UK

Harnessing energy for heating and cooling from water in the ground

Phil Jones Chair - CP3 Steering Committee philjones100@virginmedia.com 07714 203045





### WHAT IS A CODE OF PRACTICE?

- Sets Minimum Standards
- Sets Best Practice standards where possible
- Avoids reproducing existing guidance
- Provides confidence in the technology
- Connects the supply chain
- Underpins tendering & contracts
- Underpins training and accreditation
- Provides confidence to developers/specifiers
- Takes the sector to the next level





ogethe



### **CP3 is the 3<sup>rd</sup> in the series**

#### Heat networks:

Code of Practice for the UK

Raising standards for heat supply

ଞ୍ଚ ade

#### Surface water source heat pumps: Code of Practice for the UK

Harnessing energy from the sea, rivers, canals and lakes



#### **Open-loop groundwater source heat pumps:** Code of Practice for the UK

Harnessing energy for heating and cooling from water in the ground



https://www.cibse.org/knowledge/cibse-publications/cibse-codes-of-practice

CP1

2015





HPA

### Thanks to everyone involved

**Open-loop groundwater** source heat pumps: Code of Practice for the UK

Harnessing energy for heating and cooling from water in the ground



### **CP3** is a collaborative publication



Department for Business, Energy & Industrial Strategy

- Consortium funded by BEIS
- Led by CIBSE in association with HPA & GSHPA
- Supported by a 20+ strong, diverse steering committee of industry experts and stakeholders.
- With input from many more companies during the consultation process

# vironment

### With important contributions from:









#### Part A: How to use this Code

### The Code comes in 3 parts

#### A1 Introduction

- A1.1 Strategic purpose
- A1.2 What is an open-loop groundwater source heat pump?
- A1.3 Why install an open-loop groundwater source heat pump?

#### A2 Readership and scope of the Code of practice

- A2.1 Readership
- A2.2 Scope

#### A3 Structure of the Code of Practice

#### A3.1 Themes

- (A) To deliver low environmental impact
- (B) To deliver a high-performance system with a high coefficient of performance
- (C) To achieve optimum flow and return temperatures
- (D) To deliver a practical and compliant system using engineering solutions to overcome technical barriers
- (E) To deliver a cost effective reliable system with a long life and low maintenance requirements
- (F) To deliver effective metering/monitoring of the GWSHP
- (G) To deliver a safe, high quality scheme where risks are managed

#### A3.2 Responsibilities

#### Part B: Challenges and opportunities

#### B1 The heat pump

- B1.1 Types of heat pump
- B1.2 Heating and cooling
- B1.3 Key design issues

#### B2 Groundwater sources and their characteristics


- B2.1 Aquifers: the occurrence of groundwater in the subsurface
- B2.2 Water wells and boreholes
- B2.3 Groundwater from flooded mines and quarries

#### **B3** Types of installation

- B3.1 Open-loop doublet systems: abstraction with injection to aquifer
- B3.2 Open-loop systems: abstraction only with discharge to surface water or sewer
- B3.3 Standing column wells (SCWs): abstraction and injection to the same well or shaft
- B3.4 Hybrid and mixed technologies


#### B4 Challenges and opportunities

- B4.1 Heat networks (load side)
- B4.2 Source side networks (SSN)
- B4.3 Multivector and multivalent systems
- B4.4 Retrofit installations
- B4.5 Free cooling and heating
- B4.6 Aquifer thermal energy storage (ATES)



### Part C - Requirements

Themes



#### Objective 3.9: To design a data collection system to accurately record performance

#### Why is this objective important?

A comprehensive metering and monitoring system is important to ensure ongoing operational performance (see Figure 49 below for typical metering arrangements). The feasibility stage should have established the performance monitoring requirements in line with any permissions necessary, such as abstraction licence and discharge permit (see Objective 2.2). Other requirements, such as metering for relevant grants and incentives, the client's own performance records and other relevant bodies should also be determined (see Appendix C).




Figure 49 Typical metering arrangements for an open-loop GWSHP system, allowing calculation of the efficiency of the GWSHP and of the overall system (see also section B1.3); additional meters may be required in order to provide more detailed reporting, e.g. for grants and incentives

Modern BMS, BEMS, AMR or SCADA equipment (see Appendix A for definitions) can be used to monitor the installed meters/temperatures to allow ongoing performance to be determined and displayed continuously (see Figure 50).

# A more prescriptive written style

#### Minimum requirements

- 3.9.1 The metering and data system shall be designed to ensure that system efficiency can be measured and recorded. This shall also include the necessary data outputs and reports required for maintenance, environmental permissions and incentive schemes, see Figure 49.
- 3.9.2 Expected system efficiency shall be calculated to enable comparison at commissioning (5.3.4) and operation and maintenance (6.4.7) stages. (See section B1.3 for suggested methodology.)

### 'Shall' rather than 'should'

88

The requirements — Stage 3: Design


# Heat Networks Code of Practice CP1.2

# Coming Soon!





# The CP1.2 process





### The checklists

CP1 STAGE 2 Feasibility checklist			Use the drop-down to colour code columns D-G as per the key and include changes/explanation for variance/exceptions in column H							
OBJECTIVE		KEY OUTPUTS	CP1 output developed?	Included in evidence pack?	Output signed-off?	RISK level	Risk mitigation	ı	Change/Reason for variance/Exception	
	To achieve sufficient accuracy of peak heat demands and annual heat consumptions	Output 2.1a - Energy (heat, cooling & electricity) mapping report	YES	YES	YES					
		Output 2.1b - Accurate estimates of heat demands	N/A	N/A	N/A	HIGH				
		Output 2.1c - Predicted future heat demands	N/A	N/A	N/A	His				
		Output 2.1d - Report on potential stakeholders	NO	NO	NO	HIGH				
	sources and location of an energy centre	Output 2.2a - Energy Masterplanning report	N/A	N/A	N/A	HIGH	Evidence pack			
		Output 2.2b - Heat network energy model	N/A	N/A	N/A	HIGH				
		Output 2.2c - Heat source(s) assessment report	YES	N/A	N/A	HIGH				
		Output 2.2d - Energy centre location report	YES	YES	YES	MEDIUM				
	boilers and use of existing boilers	Output 2.3a - Top-up & standby heat source(s) report	YES	YES	YES	HIGH				
		Output 23b - Control strategy report	YES	YES	YES	LOW				
2.4		Output 2.4a - Target operating temperatures report	YES	YES	NO	HIGH				
		Output 2.4b - Network control strategy report	YES	N/A	N/A	HIGH				
		Output 2.4c - Heat Exchanger approach temperatures report	NO	NO	NO	HIGH				
	sizes and costs	Output 2.5a - Network pipe routes & sizing report	N/A	N/A	N/A	HIGH				
		Output 2.5b - Initial insulation thickness calculations	NO			HIGH				
		Output 2.5c - Initial network cost calculations	YES	YES	YES	HIGH				
2.6	To determine building connection costs including	Output 2.6a - Direct/indirect connection report	YES	YES	YES	HIGH				

### Building the evidence pack

## Assessing performance against targets

STAGE 2 Feasibility performance targets			Calculated & included in evidence pack?	Output signed-off?	RISK level		Risk mitigation	Change/Reason for variance/Ex	ception
	ENERGY CENTRE - Average variable cost (p/kWh)		NO	YES	MEDIUM				
	ENERGY CENTRE - Average fixed costs (£/yr)		NO	YES	HIGH				
ECONOMIC VIABILITY Cost of heat delivered p/kWh	BUILDING/BLOCK (Additional to EC) - Average variable cost (p/kWh) [Block by block if different]		YES	YES	HIGH				
(Annual average all inclusive)	BUILDING/BLOCK (Additional to EC) - Average fixed cost (£/yr) [Block by block if different]		YES	YES	HIGH				
	DWELLING - Average variable cost (p/kWh)		YES	YES	HIGH				
	DWELLING - Average fixed costs (£/dwelling/yr)		YES	YES	HIGH		Does it do what the client asked for in the first place?		
ENERGY CENTRE EFFICIENCY (% annual average all inclusive)	ENERGY CENTRE PLANT EFFICIENCY (%) of each plant item e.g. LZC1, LZC2, Boilers etc		YES	YES	HIGH				
	ENERGY CENTRE - Primary heat network loss (kWh/yr)		YES	YES	HIGH				
	BUILDING/BLOCK - Average primary Summer return temperature at the building/block (*C)		YES	YES	HIGH				
	BUILDING/BLOCK - Average primary Winter return temperature at the building/block (*C)		YES	YES	HIGH				
NETWORK HEAT LOSSES (Annual average kWh/yr)	BUILDING/BLOCK - Secondary heat network loss (kWh/dwelling/yr)		YES	YES	HIGH				
	DWELLING - HIU Average return temperature based on HIU performance and space heating design and set up (°C)		YES	YES	HIGH				
	DWELLING - HIU standby heat losses (W)		YES	YES	HIGH				
	DWELLING - Time to deliver 45°C to the kitchen tap		YES	YES	HIGH				
ENVIRONMENTAL Heat carbon intensity Kg CO2/kWh heat	ENERGY CENTRE - Kg CO <sub>2</sub> /kWh heat (Annual average all inclusive)		YES	YES	HIGH				

# Sign-off at each stage

<b>STAGE 2 Feasibility SIGN-</b>	OFF		STAGE 2	Date both	KEY Risk mitigation actions	KEY Changes/Reason for variance/Exception			
STAGE 2 I Cusionity State			fully	fully					
			signed-off?	signed-off?					
Have all the CP1 outputs been produced for STAGE 2?	Client signature	Client technical advisor signature	YES						
Have all the agreed performance targets been set for STAGE 2?	Client signature	Client technical advisor signature	N/A						
Have the STAGE 2 outputs/targets been included in the evidence pack?	Client signature	Client technical advisor signature	NO						
Has the level of risk been allocated to the STAGE 2 outputs/targets?	Client signature	Client technical advisor signature							
Has an optional independent assessment been carried out and reported to the client	Client signature	Heat Network Consultant sígnatur	YES						

### A more formalised approach right across the supply chain



# THE HEAT SECTOR JUNGLE

An unregulated forest


Unconnected supply chains

Developers lack confidence
Customer dissatisfaction

## REGULATED, SUNLIT UPLANDS

- Minimum standards
- Connected supply chains
- Confidence for developers
- Customer satisfaction
- A regulated heat sector

Codes of Practice will help us get there



for heating and cooling



philjones100@virginmedia.com 07714 203045 Open-loop groundwater source heat pumps: Code of Practice for the UK

Harnessing energy for heating and cooling from water in the ground

