Utilities - Continual Improvement

PE Welding

- Electro Fusion
- Pressure Testing



Steve Gordon



PE Jointing Fusion Welding

Electrofusion Welding of PE

Ideally, this System

Should perform like this:





Service Failures of Electrofusion Joints



And not this:





Electrofusion Fitting Failures

- Majority of problems seen are:
- Unsatisfactory training
- Poor welding practices: Clamping (Misalignment), Scraping, Moisture and Contamination
- Poor or unsuitable equipment
- Excessive pipe ovality



Training perception of trench welding?








Reality







Understanding Electro Fusion Welding Principles



Exova

Why do we scrape pe pipes?





Pigmentation

UV Stabiliser Packages

Oxidisation



SCRAPING






PREFERRED METHOD



Mechanical scrapers provide a uniformed removal of between 0.2 to 0.4mm during pipe end preparation



Hand Scraping





CONTAMINATION





CONTAMINATION


When contamination is present on the pipe or coupler, fusion becomes increasing more difficult to achieve!





WIS 4 32 08

| >75% Ductile and | K > 1.7 | Pass | Satisfactory |
|------------------|--|----------------------|------------------------|
| <75% Ductile and | K > 1.7 | Technical failure | Problems very unlikely |
| <75% Ductile and | 1.2 <k<1.7< th=""><th>Non-critical failure</th><th>Problems unlikely</th></k<1.7<> | Non-critical failure | Problems unlikely |
| <75% ductile and | K < 1.2 | Critical failure | Problems likely |





CONTAMINATION





ALIGNMENT - OVALITY



Suitable alignment clamps can assist with re-rounding of pipe




MISALIGNMENT






MISALIGNMENT




Pipe misaligned into EF fitting

During fusion heat & pressure create movement of wires






MISALIGNMENT





Clamping/ Misalignment Misalignment

- lacksquare
- Wire movement •
- Overheating





Why Audit – what do we find?







Improving Site Quality


- Site PE Audits, Testing and coaching
- Giving clients and partners an understanding of the quality being installed.
- Highlights any potential failures







ENERGY GRAPH: DUCTILE JOINT




Elongation (mm)



16,17,18,19

ENERGY GRAPH: BRITTLE JOINT




Elongation (mm)



20,21,22

Lab UKAS Schedule -**Failure Investigation**



Schedule of Accreditation locued by United Kingdom Accreditation Service 21 - 47 High Street, Feltham, Middlesex, TW13 4UN, UK

Exova (UK) Ltd 6 Coronet Way Centenary Park 2130 Eooles Manohecter Accredited to ISO/IEC 17026:2006 M60 1RE

Exova (UK) Ltd

Issue No: 007 Issue date: 29 July 2009

Contact: Mr D Lowe

Tel: +44 (0)161-787 3250 Fax: +44 (0)161 787 3251 E-Mail: david.lowe@exova.com

Website: www.exova.com

Testing performed at the above address only

DETAIL OF ACCREDITATION

| Materials/Products tested | Type of test/Properties measured/Range of measurement | Standard specifications/ Equipment/Techniques used |
|---|--|--|
| PLASTICS including PE, PVC and GRP and thermoplastic liners. | Mechanical and Physical Tests | |
| | Tensile Strength, Strain and Modulus | 80 EN 180 527-1;1996 80 EN 180 527-2;1996 83 EN 180 527-3;1996 80 EN 180 527-4;1997 88 4994;1987 |
| | Lap Shear | BS 4994:1987 (B.9) |
| | Shear Strength of Bond | BS 4994:1987 (B.10) |
| | Short-term Flexural Properties | BS EN ISO 178:2003 BS EN ISO 14125:1998 WIS 4-34-02, April 1985, Issue 1 WIS 4-34-04, March 1995, Issue 2 |
| | Long-term Flexural Creep Modulus | Documented In-house Method PDL-SOP09 |
| | Butt Fusion Jointing and Electro fusion Weld Tests | WIS 4-32-08, April 2002, Issue 3 WIS 4-32-14, March 1995, Issue 1 |
| | Fracture Toughness | Documented In-house Method PDL-SOP12 WIS 4-32-17, August 2001, Issue 2 |
| | Charpy Impact | 88 EN ISO 179:1997 88 EN ISO 179-1:2001 WIS 4-32-17, August 2001, Issue 2 Documented In-house Method PDL-SOP15 |
| | Peel Test | 88 4994:1987 |

Assessment Hanager: 083 (2130Testing Single_007)

Exova






Type 2 Test Analysis


| n | Assessment | |
|-----------------|--------------------------|--|
| < 0.04 | Air Indicated | |
| 0.04 < n < 0.05 | Pass Compacted Ground | |
| 0.05 < n < 0.08 | Pass Intermediate Ground | |
| 0.08 < n < 0.10 | Pass Exposed Pipe | |
| n > 0.10 | Leakage Indicated | |



Expected PE Decay Curves







Pressure Test Equipment: Loggers

GPS Data Log Technology (ANT Hire)

No more down time for operator as test is remotely accessed
Remote dialling access allows instant results for critical tests
Validation of test data and location is confirmed
Individual web access (paper-less trail)
Professional analysis at lower costs (Exova)









Thank you

Questions?

