

Mildmay Community Centre -Certified Passive House

Firat Ucer

Specification Manager Renewable Energy Systems

- A history of generation:

665m² structure originally built in the early 1900's to house generators for the tram network.

The building became derelict in the late 1960s.

It became a community centre after local residents lobbied Islington Council for possession of the building in the 1970s.



Historic photo before refurbishment

Before refurbishment:

- Un-insulated asbestos roof
- Depressing appearance
- Confusing entrances
- No doors to garden



South elevation before refurbishment

Before refurbishment:

- Metal framed, single glazed, draughty windows
- No windows to basement
- Freezing draughts swept across basement from ventilation grilles



South elevation before refurbishment

Before refurbishment:

- Gloomy, depressing spaces
- Echo made hearing or engaging in conversation difficult particularly for the elderly
- Bad layout and shortage of space
- Freezing cold in Winter!

The main hall before refurbishment

0


Before refurbishment:

- Difficult to achieve comfortable conditions in winter. Office extension was hot in winter, while main hall was often too cold for sedentary activities, particularly for the elderly
- Total energy demand 581kWh/m²/yr if 21°C winter temps maintained (but 272 kWh/m²/yr in reality due to high energy cost)
- Energy bills over £ 10,000 a year for an organisation with turnover of £60,000 a year



Gigantic gas boiler and virtually un-insulated tank

Mildmay Centre - holistic approach




Mildmay Centre - after refurbishment

The UK's first fully certified non-domestic passivhaus refurbishment



The refurbished Mayville Community Centre South Facade



The main hall after refurbishment



Community building in the main hall



Mayville Community Centre



Lower Ground floor plan

1 Heat recovery ventilation unit



Provides continuous fresh air to the community centre, and saves heat from WCs and kitchens to warm fresh air for the office, main hall, dining room IT suite etc. The system saves about 10 times more energy than it uses! It is located in the plant room. The filter needs changing every 3 months in London air.







4 Heat recovery ventilation control panel



These vents remove possible stale and damp air from the kitchen, main hall and WC's. The ventilation runs 7am - 7pm. The extract air vent filter in the kitchen needs to be vacuumed about every 3 months depending on how much cooking is done.

The heat recovery

warmed in winter.

vents

ventilation unit keeps

the air fresh and pre-

using these fresh air



.



This building is a Retro-fit Passivhaus.

The term passivhaus refers to an advanced low energy construction

winter and summer. They typically achieve a heating saving of 90%

compared to existing housing. Passivhaus buildings are easy to live

in and require little maintenance, but they do have some important

standard for buildings, which have excellent comfort conditions in both



6 Night cooling

2)

Office space

To keep cool in the summer take advantage of colder night time temperatures outside by leaving the windows open in the "tilt" position overnight (subject to site security). If it's hotter outside in the day you can shut the windows and external blinds.

12

Dining area

3

7 Timer for ventilation



8 CO2 Sensor for main hall ventilation

Due to the large air volume in the main hall, it is only necessary to add fresh air when larger groups of people raise the CO2 level to around 1000ppm



features, which are explained in this guide. The features are simple to

operate, but a full understanding will help you get the lowest energy

consumption and best comfort. This guide has been design by Alan

3

Simple, easily understood

temperatures

thermostatic radiator valves give

individuals control of their space

A smaller Tank

for radiator use

Clarke and bere:architects for you (the user) to understand how a

passivhaus works and how to operate the controls in this house.

herap

IT Suite

9 Radiators and thermostatic valves

Hot water is always

due to the tank being

verv well insulated so

that the water will not

cool down overnight.

For bathroom +

ready in the tank this is

MPC

2

First floor plan

10 Hot water storage

-

2

12 Fire alarm control



This is the central fire alarm control, located in the entrance hall

Existing Building naci Gardo

Each feature is labelled on the drawings below, highlighting their

corresponding text. Please take the time to read this guide and


locations and briefly explaining how to operate them in the

Section B-B

13 Lighting control

familiarise vourself with the controls.





To provide heat for

domestic hot water

tank and heating tank.

Roo

liah

Studio



15 Rain water (grey water)



16 Electrical sub metering



These submeters can be illuminated by pressing a button on the face. We are measuring data every monday for research purposes.

Viessmann Werke

0

Heating via a Vitocal 300G 7.8kw ground-source heat pump

Restricted available land meant the ground loops had to be decked


Radiator circuit designed with a flow temperature up to 45°C

DHW supported by 3m² Vitosol 300-T Solar Thermal Tubes


Thermostat & controls in the main hall


Building now heated totally by electric

127m² photovoltaic panels on 2 roofs offset electric consumption










Energy performance comparison before and after retrofit, first year of monitoring, 2012

80% reduction in energy consumption

Mayville Passivhaus Community Centre Yearly energy consumption comparison Before retrofit (gas + electricity bills Jan 2009 Dec 2009) And after refurbishment all electric building (sub metering data: EDF grid import + PVs* Jan 2012 Dec 2012)



* data between January 2012 - August 2012 was collected before the PV export sub-meter installed; for the purposes of this comparison it was assumed that all the electricity generated by the PV arrays was used entirely in the building, nothing exported back to the grid. From September 2012 the figures reflect the amount of electricity produced by the PVs and actually used by the building

Monitoring data: energy consumption by end-use

Between January 2013- December 2013, the ground source heat pump used approx. 3% of the total energy used in the building (solid red colour in the chart below)

7.00 Other non-metered loads (difference between the total electricity consumed** and total submetered) GSHP kWh manual reading (all combined submeters*) *Note: direct-electric heater not connected until 20th May 2013 Kitchen 6.00 Rain water pump Lights and Power - ground floor and basement Sewage pump Lights and power - 1st floor 5.00 00 (kWh/m2) Ventilation (fan + heater frost coil) Electricity consumption 2.00 1.00 0.00 January 2013 February 2013 March 2013 April 2013 May 2013 June 2013 July 2013 August 2013 September 2013 October 2013 November 2013 December 2013

Mayville Centre - electricity consumption by end- use - kWh/m2/month - January 2013-December 2013

Note: PV export meter not working after April 2013. PV export to the grid assumptions made based on metered data for PV generation and total loads (submeters)



H&V Awards 2014 © Viessmann Werke

Thank You