



# Large Water Source Heat Pumps – The Swedish Experience

Jan-Erik Nowacki

**SKVP** 

**KTH** 

**Nowab** 

NeoEnergy


All UK enquiries to: Nic Wincott:

01223 781940 or 07836 661551

nic.wincott@neoenergy.co.uk



### Sediment heat exchanger



Skåvsjöholm outside Stockholm 17 km of pipe buried in the sea bed Weights counteract ice buoyancy ~40 parallel circuits

Heating power 300 kW
Cooling capacity 200 kW
Built 1994 still works fine
Hotel 91 guestrooms + 16 lectureCOP 3→4


Investment around 300 000 € (indexed to 2014) Utilization time 3000 h/year

Saved energy 200 x 3000 = 600 000 kWh/year Alternative cost 0.1 €/kWh (Oil = 0,15...) Saved money 60 000 €/year

Payback period 300 000 / 60 000 = 5 years

# Vaasa Finland drilled collector

into the sediments




Warm sediment 14 °C brine in, every autumn

No "anchor"-risk

Special pipes Refla Demands drilling


Distribution of brine to the individual houses

1.2 GWh, 400 kW 9 kW → 22 kW/HP





#### Sea water - loads the bedrock summertime




Näsbypark Castle



### Näsby park Castle

Bedrock heat storage loaded from the sea





## Some larger heat pumps





Ropsten 250 MW heat – has delivered 60% of the heat to Stockholm COP 3

Also used for district cooling



### Ropsten - some more data (2012)

- Built around 1987 totally depreciated by now
- Two stages with a medium pressure tank
- Can produce 80 °C forward temperature
- Can use +2 °C sea water while heating (two intakes surface/bottom)
- 4 x 27 MW R22 heat pumps turbo (Sultzer→Axima→Cofely)
   COP = 3.21, leaked 360 kg = 0.5%
- 2 x 24 MW R134a (retrofitted as above)
   COP = 2.86, leaked 0 kg
- 4 x 25 MW R134a ABB turbo on barge (→ Siemens)
   COP = 2.68, leaked 1490 kg = 1.7% also for district cooling
- Direct cooling from sea water 74 MW
- Excellent business... marginally ~ 5 times economic gain




#### Hammarby sewage water heat pump



Seven HP, 225 MW heat totally Sewage from 700 000 person equivalents COP 3.5 produces 1.24 TWh heat/year Utilisation 5500 h/year Also used for district cooling




Heat taken up from various sources to district heating networks (2007)






# **Delivered** heat to district heating networks from large heat pumps





## Some methods to exchange heat






#### Common Shell and Tube heat



exchangers

The **Taprogge** cleaning system





http://www.taprogge.de/products-and-services/in-ta-sR/cleaning-balls/index.htm

The AHTT cleaning system 4-way reversing valve and:

http://www.heattransfer.com.au/?page\_id=477

#### A new method.....



Should be able to use 0 °C sea water



2014-05-20 16.50.46.mov